



QUALITY CONTROL DISTRICT LABORATORY
KERALA WATER AUTHORITY
CHAVARA, KARUNAGAPPALLY P.O, KOLLAM - 690518
REPORT ON ANALYSIS OF WATER

Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/100 ml	Shall not be detected/100 ml	IS 15185 : 2016	PRESENT
2	E. Coli/100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT

Report no-2024/QCSDL/CVR/826-N DATE:18/06/2024

Customer Name & Address: PRINCIPAL VALIYAM CENTRAL SCHOOL EDAPPALLYCOTTA CHAVARA PIN :691583 PHONE : 9446791491

1. Date of Sample received: 14/06/2024
2. Sampling done by: Health Inspector, CHC Chavara.
3. Sample Quantity : 250 ml
4. Source of Sample : Tube Well Water
5. Sample code:2024/QCSDL/CVR/826-N
6. Test Performing Dates
From : 14/06/2024 To : 15/06/2024

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

* End of Report *


BACTERIOLOGIST
QUALITY CONTROL SUB DISTRICT LAB
KERALA WATER AUTHORITY
CHAVARA